




REVISIONS				
ZONE	REV	DESCRIPTION	DATE	APPROVED
	A	REVISED INTERNAL DIMENSIONS	11/04/05	



5' X 5' X 4' ID ELECTRICAL VAULT

MODEL No. EV722-4
 NYSEG No. 262-722-00
 PMLD No. MAN730

Concrete 5000 psi. @ 28 days, 5-6% Air Entrainment (1.63 yds)
 Reinforcement: #4 Rebar at 6" centers, both ways (350 Lf)
 Two P-1000 Unistruts per wall
 One PS535T Dayton Swift Lift Pin Centered in Each Wall
 Estimated Weight: 6,500 Lbs

CBS
 Concrete Building Supply
 Quality Block, Masonry and Precast Products Since 1938
 PHONE: 563-0700
 WWW.concretebuildingsupply.com FAX: 563-1392

ELECTRICAL VAULT EV-722-4

SIZE	DRAWN BY:	DWG NO.	REV
B	DAVE B.	EV-722-4	A

SCALE	DATE:	SHEET
1/32"=1"	5/11/05	1 OF 1